

TABLE A-1

Public Community Water Systems Groundwater Interference Project
PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located
(Data Entered Into Groundwater Interference Geodatabase)

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0005208	ALPINE HAVEN	WELL 1B	52	52	Westfield	2/1/1990 pumping test report for Wells 1 & 2 (Con-Test) w/no observation wells in 1,000' monitoring radius.
VT0005208	ALPINE HAVEN	WELL 2	51	51	Westfield	2/1/1990 pumping test report for Wells 1 & 2 (Con-Test) w/no observation wells in 1,000' monitoring radius. 1/18/05 source evaluation report for Wells 2 & 3 (Hoffer Consulting, Inc.)
VT0005208	ALPINE HAVEN	WELL 3	29889	29889	Westfield	Well drilled 10/5/2004. 1/18/05 source evaluation report for Wells 2 & 3 (Hoffer Consulting, Inc.). No off-site observation wells & no interference w/other Alpine Haven wells (1B & 2).
VT0005110	AQUA HAVEN	WELL	40	40	East Haven	Well drilled 7/10/1992. 9/14/1992 pump test report (Wagner, Heindel, and Noyes).
VT0005397	BATTLEGROUNDS CONDOMINIUM	GRAVEL WELL S-2	46723	46723	Fayston	Shallow well. 1/7/2008 source evaluation report (VHB Pioneer). No interference at existing wells.
VT0005578	BEARS CROSSING WATER SYSTEM	WELL	333	333	Dover	2/17/1982 well test report (Wagner, Heindel, & Noyes). One well monitored ("middle of the three Suntec wells") monitored w/no interference effects attributable to Bears Crossing well.
VT0005586	BLAKE HILL	ROCK WELL	218	218, 299	Woodstock	Well drilled 10/11/1979, deepened on 6/22/1984. August 1984 well & aquifer study (Wagner, Heindel, & Noyes). No interference effects noted at the four observation wells monitored during pumping test.
VT0005006	BROOKSIDE MHP	DRILLED WELL 2	103	103	Starksboro	November 2002 Limited Source Evaluation Report (South Mountain Research & Consulting)
VT0005006	BROOKSIDE MHP	DRILLED WELL 3	126	126	Starksboro	November 2002 Limited Source Evaluation Report (South Mountain Research & Consulting)
VT0005006	BROOKSIDE MHP	DRILLED WELL 1	81	81	Starksboro	November 2002 Limited Source Evaluation Report (South Mountain Research & Consulting)
VT0005503	BURKE MOUNTAIN WATER SYSTEM	WELL 3	196	196	Burke	10/18/1988 Pumping Test Report (Wehran) w/other Burke obs. wells. 5/4/1989 Source Approval Letter.
VT0005503	BURKE MOUNTAIN WATER SYSTEM	WELL #2	148	148	Burke	11/3/1982 Pumping Test Report for Wells 1&2 (WHN) w/no observation wells. 8/20/1984 pumping test w/Well #1 as obs. well. 6/15/1987 Source Approval Letter.
VT0005503	BURKE MOUNTAIN WATER SYSTEM	GRAVEL WELL #2			Burke	Gravel well. February 2007 source evaluation report (Hoffer Consulting).
VT0005503	BURKE MOUNTAIN WATER SYSTEM	GRAVEL WELL #1			Burke	Gravel well. February 2007 source evaluation report (Hoffer Consulting).
VT0020962	BUTTERFIELD COMMON SENIOR HOUSING	WELL 1	24586	24586	Dover	10/13/2004 source testing evaluation report (Lincoln Applied Geology)
VT0005149	CAMBRIDGE VILLAGE WATER	BEDROCK	0	360	Cambridge	2/22/1990 Pumping Test Report (Wagner, Heindel, & Noyes) located.
VT0005621	CHARETTE WATER SYSTEM	WELL #2	9862		Dummerston	aka Well #1. October 1998 Source Evaluation Report and August 2001 Revised Source Evaluation Report (Stevens & Associates and Brackett Geoscience)-PID E-0791.
VT0005621	CHARETTE WATER SYSTEM	WELL #4	9863		Dummerston	aka Well #2. October 1998 Source Evaluation Report and August 2001 Revised Source Evaluation Report (Stevens & Associates and Brackett Geoscience)-PID E-0791.
VT0005621	CHARETTE WATER SYSTEM	WELL #3	9864		Dummerston	October 1998 Source Evaluation Report and August 2001 Revised Source Evaluation Report (Stevens & Associates and Brackett Geoscience)-PID E-0791.
VT0005312	CHIMNEY HILL	BEDROCK WELL #7	391	391	Wilmington	Well drilled 10/13/1988. 9/23/2000 pump test report (Bannister Research & Consulting).
VT0005312	CHIMNEY HILL	BEDROCK WELL #12	477	477	Wilmington	Well drilled 9/2/1992. 8/12/1996 pumping test & analysis (Bannister Research & Consulting). No interference with observation wells.
VT0005654	CHIMNEY HILL COLCHESTER	WELL 1	0	246	Colchester	4/15/1987 Well & Aquifer Study (Wagner, Heindel, & Noyes) located.
VT0005657	CLUB SUGARBUSH WATER SYSTEM	WELL #101	15917	15917	Warren	2/21/2001 source evaluation report (Pioneer Environmental Associates)

TABLE A-1

Public Community Water Systems Groundwater Interference Project
 PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located
 (Data Entered Into Groundwater Interference Geodatabase)

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0005657	CLUB SUGARBUSH WATER SYSTEM	WELL #102	15918	15918	Warren	2/21/2001 source evaluation report (Pioneer Environmental Associates)
VT0005657	CLUB SUGARBUSH WATER SYSTEM	WELL #103	15925	15925	Warren	2/21/2001 source evaluation report (Pioneer Environmental Associates)
VT0020847	COBB HILL COHOUSING INC	WELL #3	9320	9320	Hartland	Well drilled 5/28/1999; approved yield 7.5 gpm (6/9/2000 WSD letter). 2/23/2000 source evaluation report (Hoffer Consulting).
VT0005649	COLD BROOK F D BASE AREA	WELL 21	0	354	Wilmington	Well drilled 11/13/1986. 6/3/1987 pumping test analysis (Wagner, Heindel, & Noyes).
VT0005313	COLD BROOK FIRE DISTRICT 1	003 - WELL #20	0	328	Wilmington	11/26/1985 aquifer testing & analysis (Wagner, Heindel, & Noyes)
VT0020855	COLONIAL ESTATES HOMEOWNERS ASSN	WELL #1	347		Fairfax	6/21/1990 Well & Aquifer Analysis Report (Wagner, Heindel, & Noyes)
VT0005640	COUNTRY CLUB CONDOMINIUM	ROCK WELL #3	92	92	Bolton	March 1990 Aquifer Testing Report (Wagner, Heindel, & Noyes).
VT0005194	CRAFTSBURY FIRE DISTRICT 2	WELL 4	165	165	Craftsbury	10/18/1990 Pump Test & Well Field Analysis (Wagner, Heindel, & Noyes).
VT0005217	DANBY MOUNT TABOR F D 1	WELL 1	27122	27122	Danby	Well drilled 8/19/2003. 7/12/2004 pump test report (Lincoln Applied Geology)
VT0005653	DEER CREEK CONDOMINIUMS	DEER CREEK WELL	0	557	Dover	WR 557. 9/12/1986 Rossignol Water Supply Report (Wagner, Heindel, & Noyes).
VT0020990	DORSET COMMUNITY HOUSING	WELL	30309		Dorset	Gravel well. aka East Dorset Housing. 2/25/2005 source evaluation report (Heindel and Noyes).
VT0005536	DOVER GREEN CONDOMINIUM	WELL #1	274	274	Dover	12/30/1980 Well Test Report (Wagner, Heindel, & Noyes).
VT0005646	EAGLE RISE THE VILLAGE	WELL SITE C	359	359	Manchester	7/18/1986 well evaluation (Geomapping Associates, Ltd).
VT0005562	EAGLES RESORT	WELL 1 (NEXT TO STORAGE TANK)	225	225, 13375	Waitsfield	Well drilled 11/21/1981. 12/3/1981 well test analysis (Wagner, Heindel, & Noyes) w/no off-site observation wells.
VT0005184	EAST THETFORD WATER CO	WELL	400	320	Thetford	March 1989 well testing report (Dubois & King).
VT0021020	EASTFIELD DEVELOPMENT(FORMER LOSTTREE)	PW-1	30570	30570	Fairfax	Well drilled November 2005. 44 condominium units. 4/10/2006 source evaluation report (Heindel & Noyes).
VT0005220	EASTRIDGE ACRES ASSOCIATION	BEDROCK WELL #2	211	211	Mendon	Well drilled in 1991. Combined approved yield of 60 gpm. 10/7/1992 pumping test report (Geomapping Associates).
VT0005117	FAIRFAX WATER DEPT	WELL	135	135	Fairfax	Gravel well. 9/9/1983 Well Testing Report (Wagner, Heindel, & Noyes).
VT0020415	FAIRFIELD FIRE DISTRICT 2	WELL 1	157	157	Fairfield	2/18/1993 Pump Test Report (Wagner, Heindel, & Noyes) w/no off-site observation wells.
VT0020415	FAIRFIELD FIRE DISTRICT 2	WELL 2	158	158	Fairfield	6/2/1992 Pump Test Report (Wagner, Heindel, & Noyes) w/no off-site observation wells.
VT0005647	FALL LINE TOWN HOUSES	ACORN WELL #2	566	566	Killington	11/26/1985 pumping test report (Wagner, Heindel, & Noyes).
VT0005556	GEORGIA STATION	WELL #2	685	685	Georgia	Well drilled 6/14/1990. 10/22/1990 pump test report (Wagner, Heindel, & Noyes).
VT0005619	GLAZE BROOK	WELL #1	469	469	Killington	5/3/1983 pumping test report (Wagner, Heindel, & Noyes).

TABLE A-1

Public Community Water Systems Groundwater Interference Project

PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located

(Data Entered Into Groundwater Interference Geodatabase)

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0005600	GLEN RUN CONDOMINIUM	CARINTHIA WELL	444	444	Dover	10/24/1984 report for Northbrook Water Supply-Carinthia Well (Wagner, Heindel, & Noyes).
VT0005198	GREENSBORO FIRE DISTRICT 1	WELL #3	22211	22211	Greensboro	Well drilled June 2002. Unnumbered PID file exists. 7/10/2003 Source Permit for 52 gpm. January 27, 2003 source evaluation report (Heindel & Noyes).
VT0005630	GREENSPRINGS	GREENSPRINGS WELL #1	491	491	Dover	5/8/1985 Well & Aquifer Analysis (Wagner, Heindel, & Noyes). 6/26/1989 Well Yield Increase Letter (Wagner, Heindel, & Noyes).
VT0005630	GREENSPRINGS	WELL 3/SITE C	909	909	Dover	9/2/1994 Well & Aquifer Analysis Well #3 (Lincoln Applied Geology). 11/15/1994 Revised Well #3 Well & Aquifer Testing Report (Lincoln Applied Geology).
VT0005070	HINESBURG WATER DEPT	WELL 3	1755	1755	Hinesburg	Well drilled 6/28/1996. 11/26/1996 source evaluation report (Wagner, Heindel, and Noyes); observation well map referenced, but not found, with report.
VT0005560	HOGGE PENNY INN	WELL	242	242	Rutland	Gravel well. 9/30/1980 hydrogeologic evaluation report (Wagner, Heindel, & Noyes).
VT0005655	HOLBROOK BAY COMMONS	HOLBROOK WELL	206	206	Newport	10/9/1986 well & aquifer analysis (Wagner, Heindel, & Noyes).
VT0005153	HYDE PARK FIRE DISTRICT 1	WELL	0	253	Hyde Park	Gravel well drilled 5/24/1985. August 1985 pumping test (Dufresne-Henry) w/no formal source evaluation report. VOC contamination issue at well in late 1980s to early 1990s.
VT0005633	INTERVALE AT STRATTON	WELL 2	0		Winhall	November 1984 pumping test report (Wagner, Heindel, & Noyes).
VT0005633	INTERVALE AT STRATTON	WELL 3	508		Winhall	Well drilled 6/5/1985. June 1985 Well 3 analysis report pages located (Wagner, Heindel, & Noyes).
VT0020917	JACKSON GORE OKEMO	WELL D	9216	9216	Ludlow	10/5/1999 source evaluation report (Pioneer Environmental Associates).
VT0020917	JACKSON GORE OKEMO	WELL B	7928	7928	Ludlow	5/11/1999 source evaluation report (Pioneer Environmental Associates).
VT0005565	JAY PEAK BASIN COMPLEX	WELL 9	44677		Jay	3/6/2008 Source Permit for 50 gpm; no unacceptable interference noted w/existing on-site wells. June 2007 source evaluation report (Hoffer Consulting). Added well coordinates to GIS database.
VT0005565	JAY PEAK BASIN COMPLEX	WELL #6	93	93	Jay	8/10/1988 pump test analysis (Phillips & Emberly).
VT0005078	JERICO HEIGHTS WATER COOP	WELL #2	33544	33544	Jericho	Well drilled 3/20/2006. 8/11/1987 pumping test report for inactive Well #1 (Wagner, Heindel, & Noyes) located in Box 4930. 1/30/2007 source evaluation report (Heindel & Noyes).
VT0005096	JERICO UNDERHILL WATER	WELL 2	0		Jericho	Gravel well. October 1990 production well evaluation (Ground Water Associates).
VT0005156	JOHNSON VILLAGE WATER DEPT	GRAVEL WELL A	22288	22288	Johnson	Gravel well drilled 3/12/2003. 8/18/2004 source evaluation report (Heindel and Noyes).
VT0005609	KETTLE BROOK CONDOMINIUM	WELL #1	399	399	Ludlow	10/17/1984 Okemo interference summary letter/report (Wagner, Heindel, & Noyes).
VT0005609	KETTLE BROOK CONDOMINIUM	WELL #2	400	400	Ludlow	10/17/1984 Okemo interference summary letter/report (Wagner, Heindel, & Noyes).
VT0005609	KETTLE BROOK CONDOMINIUM	WELL #3	401	401	Ludlow	10/17/1984 Okemo interference summary letter/report (Wagner, Heindel, & Noyes).
VT0005609	KETTLE BROOK CONDOMINIUM	WELL #4	402	402	Ludlow	10/17/1984 Okemo interference summary letter/report (Wagner, Heindel, & Noyes).
VT0005609	KETTLE BROOK CONDOMINIUM	WELL #5	403	403	Ludlow	10/17/1984 Okemo interference summary letter/report (Wagner, Heindel, & Noyes).
VT0005590	KILLINGTON HIGH RIDGE CONDOMINIUM	WELL #2	0		Killington	1/5/1983 well analysis report (Wagner, Heindel, & Noyes).
VT0005590	KILLINGTON HIGH RIDGE CONDOMINIUM	WELL #5	492	492	Killington	June 1984 Well Test Analysis (Wagner, Heindel, & Noyes). 2/26/1992 aquifer analysis report (Wagner, Heindel, & Noyes).

TABLE A-1

Public Community Water Systems Groundwater Interference Project

PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located

(Data Entered Into Groundwater Interference Geodatabase)

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0005632	KILLINGTON UPLAND WATER CO INC	WELL #2	548	548	Killington	4/30/1985 pump test results for Wells 2 & 3 (Geomapping Associates).
VT0005632	KILLINGTON UPLAND WATER CO INC	WELL #1	51	547	Killington	5/21/1985 addendum to 4/30/1985 report w/Well #1 test (Geomapping Associates).
VT0020786	KING GEORGE SCHOOL 1 BOYS DORMS	WELL 2 (PRIMARY)	0		Sutton	Existing well installed circa 1966. 3/24/2000 pump test results report (Provan & Lorber).
VT0020456	KINGSWOOD AT MOUNT SNOW	WELL #6	DV441	441	Dover	August 1984 Pump Test Report 6 & 7 West Dover Development Corp. (Wagner, Heindel, & Noyes). No map showing off-site observation well locations (5 wells).
VT0020456	KINGSWOOD AT MOUNT SNOW	WELL #7	DV443	443	Dover	August 1984 Pump Test Report 6 & 7 West Dover Development Corp. (Wagner, Heindel, & Noyes). No map showing off-site observation well locations (5 wells).
VT0005286	KNEELAND FLATS MHP	WELL 1	2800	10, 2800	Waterbury	Well 1 deepened to 598 feet 6/19/1996. 10/19/1996 pumping test & analysis (Bannister Research & Consulting).
VT0005452	KURN HATTIN BOYS SCHOOL	NEW WELL	7617	7617	Westminster	Well drilled 4/1/1997. 12/28/1998 pumping test report (Bannister Research and Consulting). Doesn't show up on GIS database.
VT0005323	LUDLOW VILLAGE WATER DEPT	PW-1	22508	22508	Ludlow	Gravel well drilled 8/18/2002. January 2003 source evaluation report (Hoffer Consulting).
VT0005112	LUNENBURG FIRE DISTRICT 1	WELL 6	191	191	Lunenburg	12/28/1994 source evaluation report (Hydrosorce Associates).
VT0005112	LUNENBURG FIRE DISTRICT 1	WELL 3	152	152	Lunenburg	3/12/1992 pump tests and analysis (Wagner, Heindel, & Noyes). No site map w/report.
VT0005112	LUNENBURG FIRE DISTRICT 1	WELL 4	0		Lunenburg	3/12/1992 pump tests and analysis (Wagner, Heindel, & Noyes). No site map w/report.
VT0020000	LYMAN MEADOWS	WELL	263	263	Hinesburg	May 1988 Pump Test & Analysis (Wehran Engineering). Supersedes April 1987 72-hr pumping test.
VT0005564	MAD RIVER MEADOWS	WELL	220	220	Waitsfield	7/31/1982 well test summary (Deer Path Associates).
VT0005294	MAGIC VILLAGE WATER COOP	WELL 2	190	190	Londonderry	aka Middle Well. 8/17/2004 source testing evaluation report (Lincoln Applied Geology).
VT0005294	MAGIC VILLAGE WATER COOP	WELL 1	18579	219	Londonderry	WR 18579. Well deepened 1/25/2002. 8/17/2004 source testing evaluation report (Lincoln Applied Geology). Aka Main Well.
VT0005385	MANSFIELD VIEW WATER CORP	WELL 4	19249	19249	Stowe	Well drilled 10/9/2001. Hoffer & Associates pumping test report not located in WSD files.
VT0005607	MAPLE LANE NURSING HOME	WELL #2	BG9092	19092	Barton	August 2003 Source Evaluation Report (Heindel & Noyes)
VT0005269	MARSHFIELD WATER SYSTEM	WELL	87	220	Marshfield	1/19/1996 well & aquifer study (Nelson, Heindel, & Noyes).
VT0005291	MOUNT SNOW VILLAGE ASSOCIATION	WELL 2	27529	27529	Dover	Well drilled 5/18/2004. 12/17/2004 source evaluation report (Lincoln Applied Geology).
VT0005539	MOUNTAIN GREEN CONDOMINIUM	ROCK WELL #2	1629	1629	Killington	6/5/1997 pumping test report (Lincoln Applied Geology).
VT0005539	MOUNTAIN GREEN CONDOMINIUM	ROCK WELL #1	431	431	Killington	Pumping test reports from Jul, Aug, & Sep 1981 (Wright Engineering) and April 1983 & May 1984 (Wagner, Heindel, & Noyes).
VT0005577	MOUNTAIN SIDE CONDOMINIUM	WELL	410	410	Londonderry	8/2/1982 well analysis (David L. Tarbox & Associates).
VT0005281	MOUNTAIN WATER COMPANY	WELL #4	359	359	Warren	10/9/1984 memo re:water well yields (Wagner, Heindel, & Noyes). 8/22/1984 well and aquifer study (Wagner, Heindel, & Noyes).
VT0005281	MOUNTAIN WATER COMPANY	WELL #5	355	355	Warren	10/9/1984 memo re:water well yields (Wagner, Heindel, & Noyes). 8/22/1984 well and aquifer study (Wagner, Heindel, & Noyes).

TABLE A-1**Public Community Water Systems Groundwater Interference Project****PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located****(Data Entered Into Groundwater Interference Geodatabase)**

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0005281	MOUNTAIN WATER COMPANY	WELL #6	357	357	Warren	10/9/1984 memo re:water well yields (Wagner, Heindel, & Noyes). 8/22/1984 well and aquifer study (Wagner, Heindel, & Noyes).
VT0005281	MOUNTAIN WATER COMPANY	WELL #7	358	358	Warren	10/9/1984 memo re:water well yields (Wagner, Heindel, & Noyes). 8/22/1984 well and aquifer study (Wagner, Heindel, & Noyes).
VT0005281	MOUNTAIN WATER COMPANY	LP-1 WELL	542	542	Warren	4/5/2005 source evaluation report (Pioneer Environmental Associates, LLC.).
VT0005281	MOUNTAIN WATER COMPANY	LP-2 WELL	543	543	Warren	4/5/2005 source evaluation report (Pioneer Environmental Associates, LLC.).
VT0005281	MOUNTAIN WATER COMPANY	LP-3 WELL	544	544	Warren	4/5/2005 source evaluation report (Pioneer Environmental Associates, LLC.).
VT0005281	MOUNTAIN WATER COMPANY	LP-4 WELL	545	545	Warren	4/5/2005 source evaluation report (Pioneer Environmental Associates, LLC.).
VT0005281	MOUNTAIN WATER COMPANY	WELL #1	375		Warren	6/9/1980 bedrock aquifer evaluation (Wagner, Heindel, & Noyes).
VT0005281	MOUNTAIN WATER COMPANY	WELL #2	374		Warren	6/9/1980 bedrock aquifer evaluation (Wagner, Heindel, & Noyes).
VT0005281	MOUNTAIN WATER COMPANY	WELL #3	354		Warren	6/9/1980 bedrock aquifer evaluation (Wagner, Heindel, & Noyes).
VT0020003	MOUNTAINDALE	MOUNTAINDALE WELL	687	687	Dover	9/16/1988 Pump Test Analysis Report (Wagner, Heindel, & Noyes).
VT0005601	MURRAY HILL	WELL 2	15799	93	Montpelier	Well drilled 1983. 8/1/1983 pump test analysis (Michael D. Wurth, Consulting Geologist) superseded by 6/4/1984 pump test analysis (Michael D. Wurth, Consulting Geologist). No off-site observation wells.
VT0005601	MURRAY HILL	WELL 4	15851	15851	Montpelier	Well drilled December 2000. September 2001 source evaluation report (Hoffer Consulting).
VT0005204	NEWPORT CENTER WATER SYSTEM	WELL HSA 1	341	341	Newport	3/3/1995 hydrogeologic source evaluation (HydroSource Associates).
VT0005204	NEWPORT CENTER WATER SYSTEM	WELL HSA 2	342	342	Newport	3/3/1995 hydrogeologic source evaluation (HydroSource Associates).
VT0005202	NEWPORT CITY WATER SYSTEM	WELL 2A	20298	20298	Newport City	Gravel well drilled 7/12/2004. 2/25/2005 pump test program report (Otter Creek Engineering).
VT0020002	NORTH HARBOR	WELL #1	217	217	Colchester	12/2/1985 Aquifer Testing & Analysis (Wagner, Heindel, & Noyes) located.
VT0020002	NORTH HARBOR	WELL #3	369	369	Colchester	2/5/1996 Pump Test & Analysis (Bannister Research & Consulting) located.
VT0020002	NORTH HARBOR	WELL #2	668	668	Colchester	7/13/1987 Aquifer Testing & Analysis (Wagner, Heindel, & Noyes) located.
VT0005559	NORTHBROOK COUNTRY ESTATES	WELL 2 PRODUCTION WELL	610	610	Killington	8/4/1987 Well & Aquifer Analysis Report (Wagner, Heindel, and Noyes).
VT0020508	OKEMO SOLITUDE	WELL 2	690	690	Ludlow	3/19/1991 well & aquifer analysis (Wagner, Heindel, & Noyes).
VT0020508	OKEMO SOLITUDE	WELL 3	689	689	Ludlow	3/19/1991 well & aquifer analysis (Wagner, Heindel, & Noyes).
VT0020508	OKEMO SOLITUDE	WELL 1	700	700, 4483	Ludlow	3/21/1990 well & aquifer analysis for Well 1 only (Wagner, Heindel, & Noyes). 3/19/1991 well & aquifer analysis (Wagner, Heindel, & Noyes). 10/11/1996 additional pumping test for increase in yield (Wagner, Heindel, & Noyes).
VT0020508	OKEMO SOLITUDE	97-1	3720	3720	Ludlow	9/24/1997 source evaluation report (Pioneer Environmental).

TABLE A-1

Public Community Water Systems Groundwater Interference Project

PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located

(Data Entered Into Groundwater Interference Geodatabase)

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0020508	OKEMO SOLITUDE	97-2 (WELL #5)	3721	3721	Ludlow	9/24/1997 source evaluation report (Pioneer Environmental).
VT0020508	OKEMO SOLITUDE	97-3 (WELL #6)	4415	4415	Ludlow	9/24/1997 source evaluation report (Pioneer Environmental).
VT0005325	OKEMO TRAILSIDE CONDOMINIUM	WELL #4	196		Ludlow	4/3/1985 pumping test report (Wagner & Associates).
VT0005325	OKEMO TRAILSIDE CONDOMINIUM	WELL #A-1	0		Ludlow	6/25/1986 pumping test report (Wagner & Associates)
VT0005325	OKEMO TRAILSIDE CONDOMINIUM	WELL #A-2	447	447	Ludlow	6/5/1985 pumping test report (Wagner & Associates)
VT0020091	ORMSBY HILL WATER SYSTEM	WELL #2	388464	388, 464	Manchester	2/24/1989 aquifer testing & analysis (The Johnson Company).
VT0005042	PEACHAM FIRE DISTRICT 1	WELL 2	1477	14700	Peacham	Well drilled 3/22/2000. 9/26/2000 source evaluation report (Wagner, Heindel, and Noyes). 72-hr test @ 16.9 gpm w/135' s.w. Approved yield of 14 gpm.
VT0005162	PINECREST MOBILE HOME PARK	WELL 2	46773	46773	Morristown	Gravel well. Former well was WR 78. New Well #2 has been permitted. 11/30/2007 source testing report (Waite Environmental Management). Added well location coordinates to GIS database.
VT0005592	PIPER RIDGE CONDOMINIUM	WELL #4	0		Winhall	1/12/1984 well & aquifer analysis (Wagner, Heindel, & Noyes).
VT0005592	PIPER RIDGE CONDOMINIUM	WELL #1	0		Winhall	Initially tested in May 1973 with stabilized water level of 185' at 21 gpm. October 1983 pumping test & analysis (Wagner, Heindel, & Noyes).
VT0005592	PIPER RIDGE CONDOMINIUM	WELL #2	469	468	Winhall	October 1983 pumping test & analysis (Wagner, Heindel, & Noyes).
VT0005592	PIPER RIDGE CONDOMINIUM	WELL #3	468	469	Winhall	October 1983 pumping test & analysis (Wagner, Heindel, & Noyes).
VT0020734	POWNALE FIRE DISTRICT 2	WELL 1 (GRAVEL WELL)	5243	5243	Pownal	Gravel well. 6/30/1997 source evaluation report (Lincoln Applied Geology). 3/10/1998 source evaluation report letter (Lincoln Applied Geology).
VT0020934	PUTNEY WATER SYSTEM	WELL #3	0		Putney	Source permit issued 5/6/2004 for 138 gpm. Gravel-packed well finished 1/2/2004, 46' deep. 1/21-29/2004 pumping test (Otter Creek Engineering); no interference effects noted in monitored bedrock well sources.
VT0005179	RANDOLPH VILLAGE	WELL D	15224	15224	Randolph	Well drilled 1/15/2001. 9/12/2001 source evaluation report (Heindel and Noyes).
VT0005179	RANDOLPH VILLAGE	WELL F	15222	15222	Randolph	Well drilled 1/3/2001. 8/9/2001 source evaluation report (Heindel and Noyes).
VT0005179	RANDOLPH VILLAGE	WELL B	11034	11034	Randolph	Well drilled 10/13/1999. 2/2/2000 source evaluation report (Heindel and Noyes).
VT0005179	RANDOLPH VILLAGE	WELL E	15220	15220	Randolph	Well drilled 12/5/2000. 10/17/2001 source evaluation report (Heindel and Noyes).
VT0005344	RANMAR CORP MHP	WELL #2	3981	3981	Berlin	Well drilled 7/28/1997.
VT0005482	RUTLAND TOWN FIRE DISTRICT 10	WELL #10	373	373	Rutland	3/15/1999 source evaluation report (Heindel & Noyes).
VT0005636	SEASONS ON MOUNT SNOW	MAIN WELL D	DV500	500	Dover	WR 500. 8/14/1985 Well & Aquifer Study (Wagner, Heindel, & Noyes).
VT0020434	SLOPESIDE CONDOMINIUM	WELL NO. 5	86/22240	86/22240	Jay	Formerly WR 86 drilled 8/14/1986. Well deepened 9/5/2002. Original pump test analysis dated 9/26/1986 (The Johnson Co.).
VT0005151	SMUGGLERS NOTCH WATER SYSTEM	WELL2C	386	386	Cambridge	4/18/1991 Pumping Test Report (Wagner, Heindel, & Noyes).

TABLE A-1

Public Community Water Systems Groundwater Interference Project

PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located

(Data Entered Into Groundwater Interference Geodatabase)

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0005151	SMUGGLERS NOTCH WATER SYSTEM	WELL W	33249	33249	Cambridge	Well drilled 10/10/2007. 12/13/2007 source evaluation report (Pioneer Environmental Associates). Well doesn't show up on GIS database.
VT0005151	SMUGGLERS NOTCH WATER SYSTEM	WELL LB-1	36398	36398	Cambridge	Well drilled 6/7/2006. 12/13/2007 source evaluation report (Pioneer Environmental Associates). Well doesn't show up on GIS database.
VT0005623	SNOW MOUNTAIN VILLAGE	WELL 2	577	577	Dover	3/19/1987 Aquifer Analysis Well #2 (Wagner, Heindel, & Noyes).
VT0005608	SOUTH FACE	WELL #3	317	317	Warren	1/31/1983 Well Test Summary (Deerpath Associates)
VT0005608	SOUTH FACE	WELL B	371	371	Warren	October 1984 Evaluation of Well B (Lincoln Applied Geology)
VT0005121	SOUTH GEORGIA FIRE DISTRICT	METEVIER	286, 21-A	535	Georgia	Sixth well (active) drilled December 1987. 7/6/1988 Aquifer Capacity Analysis Report for Wells A, C, D, & E (Wagner, Heindel, & Noyes); doesn't include currently active well. 8/17/1988 water supply testing report (Wagner, Heindel, & Noyes) in Box 5272.
VT0005593	SOUTH VILLAGE	# 12	0		Warren	April 1983 pumping test report (Geomapping Associates).
VT0005593	SOUTH VILLAGE	# 5	385	385	Warren	Well drilled 10/22/1982. December 1982 pumping test report (Geomapping Associates).
VT0005593	SOUTH VILLAGE	# 6	0	376	Warren	Well drilled 10/27/1982. December 1982 pumping test report (Geomapping Associates).
VT0020570	SOUTHEAST STATE CORRECTIONAL FACILITY	DEEP WELL (FURTHEST FROM ROAD)	10	10	Windsor	11/20/1990 pumping test analysis (Wagner, Heindel, & Noyes).
VT0005095	ST GEORGE VILLAS	WELL #2	57	57	St. George	5/28/1999 source testing and data evaluation (KSKGeoS). 7/1/1999 interference & source yield analysis (KSKGeoS).
VT0020092	STERLING VIEW SENIOR MHP	WELL 2	341	341	Hyde Park	4/28/1993 pump test report (Wagner, Heindel, & Noyes) w/no off-site observation wells to 2,000' radius. Approved yield of 17.7 gpm (project demand) according to 8/26/1994 sanitary survey. aka Glenbrook. Well drilled 6/27/1995. June 1997 source evaluation report (Hoffer & Associates).
VT0005523	STOWE FIRE DISTRICT 4	WELL P-3			Stowe	Well log not included in WSD well completion report database.
VT0005163	STOWE WATER DEPT	EH-2	1200	1200	Stowe	Gravel well drilled 11/15/1995. January 1996 source evaluation report (Hoffer & Associates).
VT0005163	STOWE WATER DEPT	VILLAGE GREEN WELL	814	814	Stowe	Gravel well. 4/28/1989 pumping test report (WehranEnviroTech). 8/18/1989 response letter report (WehranEnviroTech).
VT0005599	SUMMIT WATER CO INC	MAIN WELL	139	139	West Windsor	3/28/1984 well & aquifer study (Wagner, Heindel, & Noyes). 8/15/1985 well interference report (Wagner, Heindel, & Noyes). 9/26/1986 phase 3 well and aquifer study (Wagner, Heindel, & Noyes).
VT0005618	SUNRISE COMMUNITY WATER SYSTEM	WELL #3	551	551	Killington	11/23/1983 pumping test report (Wagner, Heindel, & Noyes); 3/12/1985 well interference report (Wagner & Associates).
VT0005618	SUNRISE COMMUNITY WATER SYSTEM	WELL #10	532	532	Killington	12/21/1984 pumping test report (Wagner & Associates); 3/12/1985 well interference report (Wagner & Associates).
VT0005618	SUNRISE COMMUNITY WATER SYSTEM	WELL 1-A-04 (WELL 5)	28908		Killington	Well drilled 6/19/2004. 10/1/2004 source testing report (Lincoln Applied Geology).
VT0005375	TALL TIMBERS MHP	WELL 3	4359	4359	Hartford	9/8/2003 Source Evaluation Report Well 3 (Pioneer Environmental Associates)
VT0005545	TARA TOWNHOUSES	TARA D WELL	331	NOT WR 331	Dover	aka Well #2 or #5. Late 1981 Water Supply Analysis report (Wagner, Heindel, & Noyes) w/no off-system observation wells for Wells 1, 2, & 3, Box 4879. 7/15/1982 Bedrock Aquifer Study (Wagner, Heindel, & Noyes) w/testing results for Wells 1 - 4, Box 4879. 9/11/1987 Aquifer Test Report for Well #4 (formerly Well I) (Wagner, Heindel & Noyes) located in Box 5060.
VT0005181	THETFORD WATER COOP INC	WELL A	12271	12271	Thetford	Well drilled 10/15/1999. July 2000 source evaluation report (Hoffer Consulting).

TABLE A-1

Public Community Water Systems Groundwater Interference Project
 PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located
 (Data Entered Into Groundwater Interference Geodatabase)

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0005615	TIMBERCREEK CONDOMINIUM	BACK UP WELL	412		Dover	aka Well #1.
VT0005615	TIMBERCREEK CONDOMINIUM	MAIN WELL	396		Dover	aka Well #10.
VT0005597	TRAIL CREEK CONDOMINIUM	WELL #2 100'	491	491	Killington	August 1983 pumping test report (Wagner, Heindel, & Noyes).
VT0005597	TRAIL CREEK CONDOMINIUM	WELL #1 705'	490	490	Killington	September 1983 pumping test report (Wagner, Heindel, & Noyes).
VT0020151	TRAILSIDE AT MAGIC MOUNTAIN	WELL #2 10-97	551	551	Londonderry	10/27/1987 pump test analysis (Wagner, Heindel, & Noyes).
VT0020151	TRAILSIDE AT MAGIC MOUNTAIN	WELL #1 4-97	524	524	Londonderry	5/24/1987 pump test analysis (Wagner, Heindel, & Noyes). 8/12/1987 cyclic test report (Wagner, Heindel, & Noyes).
VT0020414	TRILLIUM WOODS WATER SYSTEM	WELL NUMBER 1	302		Jay	3/7/1989 pump test analysis (Wagner, Heindel, & Noyes).
VT0020986	VERNON SENIOR HOUSING	WELL 1	24564	24564	Vernon	Well drilled 4/13/2004. 3/18/2005 source testing evaluation (Lincoln Applied Geology). Not in GIS database.
VT0020986	VERNON SENIOR HOUSING	WELL 2	24581	24581	Vernon	Well drilled 7/13/2004. 3/18/2005 source testing evaluation (Lincoln Applied Geology). Not in GIS database.
VT0020100	VILLAGE AT SAWMILL FARMS	WELL #3	373	373	Dover	May 1983 Water Supply Investigation Report (Fuss & O'Neill, Inc.).
VT0020100	VILLAGE AT SAWMILL FARMS	WELL #5	375	375	Dover	May 1983 Water Supply Investigation Report (Fuss & O'Neill, Inc.).
VT0005242	WALLINGFORD FIRE DISTRICT 1	STONE MEADOW GRAVEL WELL	331	331	Wallingford	Gravel well. 2/12/1996 source evaluation report (Lincoln Applied Geology).
VT0005185	WASHINGTON FIRE DISTRICT	WELL	78	78	Washington	April 1989 preliminary engineering report (Dubois & King) w/pumping test data/analysis.
VT0021029	WEST RIVER VALLEY SENIOR HOUSING	SOURCE B	31397	31397	Townsend	Well drilled 1/23/2006. 6/2/2006 source evaluation report (Eastview Environmental).
VT0005450	WESTFORD FIRE DISTRICT 1	WELL #3	407	407	Westford	aka North Ridge Owners' Association. Well drilled 2/17/1994. June 1994 source evaluation report (Twin State Environmental).
VT0005186	WILLIAMSTOWN WATER DEPT	WELL/B1	315	315	Williamstown	April 1990 Report of Well Testing Results (Dubois & King)
VT0005186	WILLIAMSTOWN WATER DEPT	WELL/B2-2	316	316	Williamstown	April 1990 Report of Well Testing Results (Dubois & King)
VT0005399	WINDY HILL ACRES MHP	WELL #9	577	577	Springfield	Well drilled 6/1/1995. 7/6/1995 pumping test impacted Well 7 (now unused) w/no effects on Wells 3, 4, 6 and nearby Dick Moore's spring. 4/14/1997 source evaluation report (Stevens & Associates Engineering).
VT0005305	WINHALL STRATTON F D 1	SUNBOWL WELL #50	11804	11804	Stratton	10/16/2000 source evaluation report (Pioneer Environmental Associates).
VT0005305	WINHALL STRATTON F D 1	SUNBOWL WELL #51	15380	15380	Stratton	10/16/2000 source evaluation report (Pioneer Environmental Associates).
VT0005305	WINHALL STRATTON F D 1	30	0	473	Winhall	10/25/1983 Stratton water study (Wagner, Heindel, & Noyes). 8/27/1999 re-test report (Heindel & Noyes).
VT0005305	WINHALL STRATTON F D 1	18	60	60, 32143	Stratton	10/25/1983 Stratton water study (Wagner, Heindel, & Noyes). Re-developed, re-tested in 2006.
VT0005305	WINHALL STRATTON F D 1	#45	9161	9161	Stratton	2/12/1999 source evaluation report (Pioneer Environmental Associates).

TABLE A-1**Public Community Water Systems Groundwater Interference Project****PCWS Bedrock, Gravel, and Dug Wells for which Source Evaluation Reports with Observation Well Data was Located****(Data Entered Into Groundwater Interference Geodatabase)**

WSID	WS Name	Facility Name	Tag Number	WR Number	Town	Comment
VT0005305	WINHALL STRATTON F D 1	#46	4822	4822	Stratton	2/12/1999 source evaluation report (Pioneer Environmental Associates).
VT0005305	WINHALL STRATTON F D 1	WELL 35	0		Stratton	4/9/1992 well & aquifer study (Wagner, Heindel, & Noyes).
VT0005305	WINHALL STRATTON F D 1	WELL 38	0		Stratton	4/9/1992 well & aquifer study (Wagner, Heindel, & Noyes).
VT0005305	WINHALL STRATTON F D 1	#47	4488	4488	Stratton	6/30/1999 source evaluation report (Pioneer Environmental Associates).
VT0005305	WINHALL STRATTON F D 1	#48	8701	8701	Stratton	6/30/1999 source evaluation report (Pioneer Environmental Associates).
VT0005305	WINHALL STRATTON F D 1	#49	8779	8779	Stratton	6/30/1999 source evaluation report (Pioneer Environmental Associates).
VT0005305	WINHALL STRATTON F D 1	#44	128	128	Stratton	7/19/1994 pump test & analysis (Wagner, Heindel, & Noyes).
VT0005305	WINHALL STRATTON F D 1	33	0		Winhall	9/20/1984 well & aquifer analysis (Wagner, Heindel, & Noyes).
VT0005305	WINHALL STRATTON F D 1	31	0	481	Winhall	aka High Meadows Well #1. 10/25/1983 Stratton water study (Wagner, Heindel, & Noyes).
VT0005305	WINHALL STRATTON F D 1	16	58	58	Stratton	11/19/1994 well evaluation report (Wagner, Heindel, & Noyes).
VT0005305	WINHALL STRATTON F D 1	17	59	59, 32147	Stratton	Fall 1981 bedrock aquifer study (Wagner, Heindel, & Noyes). 10/25/1983 Stratton water study (Wagner, Heindel, & Noyes).
VT0005635	WINTERPLACE WATER SYSTEM	ROCKWELL 3	46371	46371	Ludlow	Fall 1981 bedrock aquifer study (Wagner, Heindel, & Noyes). 10/25/1983 Stratton water study (Wagner, Heindel, & Noyes). Re-developed, re-tested in 2006.
VT0005635	WINTERPLACE WATER SYSTEM	ROCK WELL #1	529	529	Ludlow	9/7/2007 source evaluation report (Pioneer Environmental Associates).
VT0005635	WINTERPLACE WATER SYSTEM	ROCK WELL #2	528	528	Ludlow	June 1987 well evaluation report (Ground Water Associates). No interference at off-site wells and springs and no map showing locations of off-site wells.
VT0005631	WOODS	WELL #3 (LOWER WELL) AA	569	569	Killington	June 1987 well evaluation report (Ground Water Associates). No interference at off-site wells and springs and no map showing locations of off-site wells.
VT0005631	WOODS	WELL #4 (UPPER WELL) BB	590	590	Killington	9/23/1985 Well #3 pump test (Wagner & Associates). 1/31/1986 Cyclic Test Report for Well #3 (Wagner & Associates), mentions 72-hour test performed in September 1985, mentions 7.6 gpm approval rate. Also, VDOH letters to eight observation well owners indicating no response to pumping from Well #3.
VT0005343	WOODSTOCK AQUEDUCT CO	WELL 2A	476	476	Woodstock	July 1986 pumping test (Wagner, Heindel, & Noyes).
VT0005343	WOODSTOCK AQUEDUCT CO	WELL 2B	475	475	Woodstock	Gravel well. August 1993 source evaluation report (Ground Water Associates) w/no interference effects noted at off-site observation wells and no map showing off-site observation well locations.