

State of Vermont  
Agency of Natural Resources  
Department of Environmental Conservation  
Notice of Determination of Eligibility for Categorical Exclusion

Hartland Elementary School WSID #6639  
Water System Improvements  
DWSRF Project Number WPL-184 and RF3-260

In accordance with Section VII of the Department's Environmental Review Procedures for projects funded through the Vermont/EPA Revolving Loan Fund Program, Hartland Elementary School Water System WSID #6639 has requested its proposed water improvement project be evaluated for eligibility for a Categorical Exclusion exempting the project from detailed environmental procedures required for projects having a significant environmental impact.

The project consists of abandoning the existing steel storage tank and vault, rerouting piping, and constructing a new building to house a new VFD-controlled booster pump system, the disinfection treatment system, and the system controls.

Our consideration of the Hartland Elementary School request included reviewing environmental information and documentation completed and submitted by Otter Creek Engineering, Inc. At the completion of this independent evaluation, the Department has determined the project meets the criteria for receiving a Categorical Exclusion. The project will correct water system deficiencies and does not meet any of the criteria resulting in denial of an exclusion.

Further information on the project and this determination are available for inspection at the Department of Environmental Conservation, Water Supply Division, Old Pantry Building, at 103 South Main Street, Waterbury, Vermont. In addition to the applicant, a copy of this determination will be sent to a list of stakeholders and posted on the Water Supply Division's website.

Agency of Natural Resources  
Department of Environmental Conservation  
David Mears, Commissioner

By Jean M. Nicolai for  
Gary Schultz, Director  
Water Supply Division

Dated at Waterbury, Vermont this 10th day of June, 2011