

State of Vermont
Agency of Natural Resources
Department of Environmental Conservation
Notice of Determination of Eligibility for Categorical Exclusion

Barnet FD#2, WSID #5029
Barnet, VT
Water System Improvements
DWSRF Loan RF3-318 Source and Treatment Improvements

In accordance with Section VII of the Department's Environmental Review Procedures for projects funded through the Drinking Water State Revolving Fund (DWSRF) Program, the Barnet FD#2 Water System, located in the Town of Barnet, VT has requested its proposed water improvement project be evaluated for eligibility for a categorical exclusion exempting the project from detailed environmental procedures required for projects having a significant environmental impact.

The project consists of the connection of a new drilled well and upgrade and connection of the existing well to a new treatment building and corresponding chlorine contact pipe. Well connections will be approximately 300 linear feet in length and the chlorine contact pipe will consist of approximately 600 linear feet of 8" pipe. The new treatment building will have a footprint of approximately 12' x 18'.

Our consideration of the Barnet FD#2 Water System's request included reviewing environmental information and documentation completed and submitted by their engineering consultant, Horizons Engineering. At the completion of this independent evaluation, the Department has determined the project meets the criteria for receiving a Categorical Exclusion. The project will correct water system deficiencies and does not meet any of the criteria resulting in denial of an Exclusion.

Further information on the project and this determination are available for inspection by contacting the DWSRF Program at (802) 585-4904. In addition to the applicant, a copy of this determination will be sent to a list of stakeholders and posted on the Drinking Water and Groundwater Protection Division's [Environmental Review Determination Notice](#) page.

Agency of Natural Resources
Department of Environmental Conservation
Alyssa B. Schuren, Commissioner

By 
Eric Blatt, P.E., Director
Facilities Engineering Division

Dated in Montpelier, Vermont this 3rd day of May, 2016