

State of Vermont
Agency of Natural Resources
Department of Environmental Conservation
Notice of Determination of Eligibility for Categorical Exclusion

Bellows Falls Water System, WSID #5298
Rockingham, VT
Water System Improvements
DWSRF Loan RF3-308 Contract 2016-1

In accordance with Section VII of the Department's Environmental Review Procedures for projects funded through the Drinking Water State Revolving Fund (DWSRF) Program, the Bellows Falls Water System, located in the Town of Rockingham, VT has requested its proposed water improvement project be evaluated for eligibility for a categorical exclusion exempting the project from detailed environmental procedures required for projects having a significant environmental impact.

The project consists of the replacement of approximately 6,600 linear feet of asbestos-cement (AC) transmission main with new 12-inch water main and approximately 400 feet of new 8-inch water main.

Our consideration of the Bellows Falls Water System's request included reviewing environmental information and documentation completed and submitted by their engineering consultant, Dufresne Group. At the completion of this independent evaluation, the Department has determined the project meets the criteria for receiving a Categorical Exclusion. The project will correct water system deficiencies and does not meet any of the criteria resulting in denial of an Exclusion.

Further information on the project and this determination are available for inspection by contacting the DWSRF Program at (802) 585-4904. In addition to the applicant, a copy of this determination will be sent to a list of stakeholders and posted on the Facility Engineering Division's [Environmental Review Determination Notice](#) page within five business days of notice.

Agency of Natural Resources
Department of Environmental Conservation
Alyssa B. Schuren, Commissioner

By 
Eric Blatt, P.E., Director
Facilities Engineering Division

Dated in Montpelier, Vermont this 7th day of September, 2016