

NUMBER

75-952

(For Driller's Use)

State of Vermont
DEPARTMENT OF WATER RESOURCES

WELL COMPLETION REPORT

DO NOT FILL IN

(This report must be completed and submitted to the Department of Water Resources, State Office Building, Montpelier, Vermont 05602, no later than 60 days after completion of well. Complete or line out all blanks.)

WRN 6431
Bridgewater
8-22-75
Harris (72)

WELL
OWNER Bridgewater Mill Mall Bridgewater, Vermont
Name Mailing Address

TOWN IN WHICH WELL IS LOCATED: Bridgewater (Please locate well on a large scale map to accompany this report. Maps are available on request.)

DATE WELL WAS COMPLETED: August 22, 1975

PROPOSED USE OF WELL: ☐ Domestic ☐ Agricultural ☒ Business Establishment
☐ Municipal ☐ Industrial ☐ Other (Specify)

DRILLING EQUIPMENT: ☐ Cable Tool ☐ Rotary ☒ Air Percussion
☐ Other (Specify)

TOTAL DEPTH OF WELL: 137 ft. STATIC WATER LEVEL: 40 ft.

CASING DETAILS: Length 133 ft. Diameter 6 in. Material Black steel
Weight 17 lb./ft.

SCREEN DETAILS: Make XXXXXXXXXX Material XXXXXXXXXXXXXXXXXXXXXXXXXXXX Length XXXXXXXX ft.
Diameter XXXXX in. Slot Size XXXXXXXXXXXXXXXXXXXXXXXXXXXX

METHOD OF SEALING CASING TO SCREEN OR BEDROCK: Cement

FINAL YIELD TEST: ☐ Bailed, or ☒ Pumped, or ☐ Compressed Air
48 Hours at 33 gallons per minute

Water level during yield test 100 ft.

WELL LOG

Depth From
Ground Surface

Give description of formations penetrated, such as: peat, silt, sand, gravel, clay, hardpan, shale, limestone, granite, etc. Include size of gravel (diameter) and sand (fine, medium, coarse, color of material, structure (loose, packed, cemented, hard). For example: Surface to 27 ft. fine, packed, yellow sand; to 134 ft. gray granite.

Surface to	4 ft.	Sand
4 to	90 ft.	Hardpan
90 to	137 ft.	Gravel
to	ft.	
to	ft.	

YIELD TEST DATA IN G.P.M.

If yield was tested at different depth during drilling,
List Below

<u>137</u> ft.	<u>50</u> G.P.M.
ft.	G.P.M.
ft.	G.P.M.

WATER ANALYSIS: Has water been analyzed? ☒ Yes ☐ No If Yes, Where State of Vermont
Include Analysis

DRILLED BY: Ch. Harris Signature

DOING BUSINESS AS: Dean Herrick, Inc. Company

DATE OF REPORT: October 22, 1975 WELL DRILLERS LICENSE NO. 72

TOWN: Bridgewater TOPO: 36B, D WELL/SPRING #: BWW-1

SYSTEM NAME: Bridgewater Mill Mall

OWNER/OPERATOR NAME, ADDRESS, PHONE NUMBER:

Phil Dechert (Manager)

Rte 4

Bridgewater, VT 05034

David Fadden
Janitor

672-3332

NEARBY WELLS:

672-3332

<u>Drillers log #</u>	<u>Name & Address</u>	<u>Date Drilled</u>	<u>Use</u>	<u>B/U/S</u>	<u>GPM</u>
144	Everett Olmstead	4/2/82	D	B	10
137	Vincent Gallagher	7/10/81	D	B	48
142	Joseph Lupton	10/2/81	D	B	20
71	Blanche King	11/9/73	D	B	40
72	Raymond Roberts	1/8/74	b	B	12
75	Mr Richard Thompson	1/30/74	D	u	20

COMMENTS ON LOCATIONS FROM FILES:

FIELD NOTES and DATE OF FIELD VISIT: