

WELL COMPLETION REPORT

SEP 18 2002 JUN 13 2002

WELL TAG No. 19190

(Fill In Number from Tag)

WELL LOCATION

Well Owner or Purchaser: Waldo Martell
911 Address: Handscrabble Rd.

Town: Wilmington
Subdivision Name: _____
Lot Number: _____

GEOGRAPHIC LOCATION (Complete A OR B, not both)

A. GPS Location: 44° 37.39' N 073° 05' 33" W 310 Satellite 06
Latitude Rdg. 21.0 Longitude Rdg. 31.2 (OR) # of Satellites Used (Min. 3)

B. Attach a Town Map showing location of well marked with a clear dot.

WELL TYPE (Check One)

- ☒ Bedrock
☐ Gravel
☐ Monitoring
☐ Other: _____

WELL USE (Check one)

- ☒ Domestic
☐ Public
☐ Agricultural
☐ Industrial
☐ Other: _____

REASON FOR WELL (Check one)

- ☒ New Supply
☐ Replace Existing Supply
☐ Deepen Existing Supply
☐ Additional Supply
☐ Test/Exploration
☐ Other: _____

WELL CONSTRUCTION INFORMATION

DEPTHS

To Bedrock 28 ft
Total: 220 ft.

CASING

Total Length: 38 ft
Casing Exposed: 21 in.

Diameter: 6 in.

Material: Steel

Weight: 17 lb/ft

LINER OR INNER CASING

Total Length: _____ ft.

Depth to Liner Top: _____ ft.

Diameter: _____ in.

Material: _____

Weight: _____ lb/ft

Seal Type: _____

SCREEN DETAILS

Make/Type: _____

Material: _____

Diameter: _____ in.

Depth to Screen Top: _____ ft.

Slot Size _____

Gravel Pack (Type & Size): _____

SEALING METHOD

- ☒ Drive Shoe
☐ Grouted
Grout Type: _____

YIELD TEST

Tested for 2 hr @ 12 GPM
Static Water Level 5 Ft. Below Land Surface
☐ (Check Here if Overflowing)
☐ Hydrofractured. Resulting flow= _____ GPM

WELL DRILLER INFORMATION

Drilled By: Robert Gordon

Company: Howell Drilling Lic#: 129

Signature of Qualifying Individual: Robert Gordon

WELL LOG

From To

Formation Information and
Water Bearing Fractures

28 220

G Hard Blue

COMMENTS

SITE SKETCH (Optional)

GENERAL INSTRUCTIONS:

1. Wells must be tagged within 30 days of well completion.
2. Complete and Submit this form within 90 days of well completion.
3. If you need more space , please attach extra sheet, include Tag Number.
4. If you would like to complete this form electronically on a personal computer instead of paper, call us.
5. **Variance:** When meeting the minimum isolation distances in 12.2.1.1 is physically unworkable, or the location of the subsurface disposal field can not be determined, additional protective measures must be used. Additional protection (except as otherwise specified by the Agency) shall be provided through the use of additional casing and grouting of any annular space. The well location problems shall be discussed with the owner and the final location and use of additional protective measures shall be agreed to before construction. The variance shall be noted on the Well Completion and Servicing Report.

WELL LOG GUIDELINES

Please provided descriptions of the subsurface condition encountered. The following codes can be used when filling out the overburden information:

LITHOLOGY CODES

B	Boulder, cobble	S	Sand	I	Silt
BS	Boulder & sand	SG	Sand & gravel	T	Till/Hardpan
BI	Boulder & silt	SI	Sand & silt	SO	Soil
BC	Boulder & clay	C	Clay	R	Rock, bedrock, ledge
G	Gravel	CG	Clay & gravel		
GS	Gravel & sand	CS	Clay & sand		
GI	Gravel & silt	CI	Clay & silt		

For bedrock please provide a description of the rock; such as, color, hardness, texture and rock type if known. The following guidelines can be used:

Hardness:	Soft	Color:	One Color	Rock Type—If Known
	Medium		Multiple Colors	
	Hard		% of each color	