

WELL NO. / TAG NO.

2B

(For Driller's Use)

This report must be completed and submitted to the Department of Environmental Conservation 103 South Main Street (10N), Waterbury, VT 05676 no later than 60 days after completion of the well.

State of Vermont
Dept. of Environmental Conservation
103 South Main Street (10N)
Waterbury, Vt. 05676
WELL COMPLETION REPORT

DEPARTMENT USE ONLY

E.C. _____ U.S.G.S. _____
Field Location ☐ Map area _____
Latitude _____ " Elev. _____
Longitude _____ " Topo. _____
Scale: 62,500 ☐ 25,000 ☐ 24,000 ☐
Data in Town Files ☐

Location map attached to WCR _____

1. WELL OWNER Woodstock Aqueduct Company, 16 Elm St., Woodstock, VT 05091
OR
WELL PURCHASER Same
2. LOCATION OF WELL: TOWN Woodstock SUBDIVISION _____ LOT NO. _____
3. DATE WELL WAS COMPLETED 1/15/93
4. PROPOSED USE OF WELL: ☐ Domestic, ☒ Other Public Water Supply
5. REASON FOR DRILLING WELL: ☐ New Supply, ☐ Replace Existing Supply, ☐ Deepen Existing Well, ☐ Test or Exploration,
☒ Provide Additional Supply, ☐ Other _____
6. DRILLING EQUIPMENT: ☒ Cable Tool, ☐ Rotary with A-P, ☐ Other _____
7. TYPE OF WELL: ☐ Open Hole in Bedrock, ☐ Open End Casing, ☐ Screened or Slotted, ☒ Other Gravel-Packed
8. TOTAL DEPTH OF WELL: 71 feet below land surface.
9. CASING FINISH: ☒ Above ground, Finished, ☐ Above ground, Unfinished, ☐ Buried, ☐ In Pit, ☐ Removed, ☐ None used, ☐ Other _____
10. CASING DETAILS: Total length 58 ft. Length below L.S. _____ ft. Dia. 16 in. Material _____ Wt. _____ lb./ft.
11. LINER OR INNER CASING DETAILS: Length used 58 ft. Diameter 8 in. Material _____ Weight _____ lb./ft.
12. METHOD OF SEALING CASING TO BEDROCK: ☐ Drive Shoe, ☐ Grout - type _____, Drilled _____ in. hole _____ ft. in Bedrock
☐ Other _____
13. SCREEN DETAILS: Make and Type Johnson Wire-Wrapped Stainless, Length 13 ft., Diameter 8 in.,
Slot Size 0.056", Depth to top of screen in feet below land surface 58 ft., Gravel pack if used: Gravel Size or Type #2 Cape May
14. YIELD TEST: ☐ Bailed, ☒ Pumped, ☐ Compressed Air, for 24 Hours at 127 Gallons per minute
Measured by ☐ Bucket, ☒ Orifice pipe, ☐ Wier, ☐ Meter ☐ Permanent Airline installed
15. STATIC WATER LEVEL: 4.00 feet below land surface, Date or Time measured 1/93, Overflows at _____ G.P.M.
16. WATER ANALYSIS: Has the water been analyzed? ☐ Yes ☐ No, if Yes, Where _____
17. SPECIAL NOTES: WSD ID 1194-Yield and water quality testing to be performed.

18. WELL LOG

Depth from Land Surface		Water Bearing	Formation Description	Sketch
Feet	Feet			
Ground Surface	5		Top soil	
5	11		Coarse gravel	
11	18		Grey silty sand	
18	23		Fine-coarse gravel, fine-med sand	
23	27		Silty gravel and clay	
27	48		Silty clay, trace gravel	
48	61	X	Fine-coarse gravel with silty sand (cemented 55-61)	
61	68		Grey silty sand, traces gravel	

19. SITE MAP

Show permanent structure such as buildings, septic tanks, and/or other land marks and indicate not less than two distances to the well. Indicate local street name and subdivision lot number.

20. TESTED YIELD 68 71.5 X Fine-coarse gravel, fine-coarse sand Brian Auclair
WELL DRILLED BY: _____

If the yield was tested at different depths during drilling, list below.

Feet	Gallons Per Minute

DOING BUSINESS AS: Hydro Group-Layne Well & Pump
Company or Business Name

REPORT FILED BY: _____
Authorized Signature

DATE OF REPORT: 3/22/93 WELL DRILLERS LIC. NO. 32

