

STATE OF VERMONT – DEPT. OF ENVIRONMENTAL CONSERVATION

Drinking Water & Groundwater Protection Division (DWGPD), 1 National Life Drive, Main Building – 2nd Floor,
Montpelier, VT 05620-3251

Tel. (802) 828-1535 or (802) 585-4907

WELL COMPLETION REPORT

WELL LOCATION

Well Owner or Purchaser: Scott Godbout
E-911 Address: Sadler Meadow

WELL TAG No. 49122

Town: Richmond
Subdivision Name: Sadler Meadow
Lot Number: 26

GEOGRAPHIC LOCATION (Complete A OR B, but not both) Date Well Drilled: 8-29-14

A. GPS Location: 44.42195° N 072.92475° WVT Natural Resource Atlas
Latitude Rdg Longitude Rdg GPS Make/Model # of Satellites Used (Min. 3)

B. Attach Town Map with well location marked, if not providing GPS location.

WELL TYPE (Check one)

- ☒ Bedrock
☐ Gravel
☐ Monitoring
☐ Other: _____

WELL USE (Check one)

- ☒ Residential/Non-public
☐ Public water system
☐ Agricultural
☐ Industrial
☐ Other: _____

REASON FOR WELL (Check one)

- ☒ New supply
☐ Replace existing supply
☐ Deepen existing supply
☐ Additional supply
☐ Test/exploration
☐ Geothermal
☐ Other: _____

WELL CONSTRUCTION INFORMATION

DEPTHS

To bedrock
107 ft.
Total
621 ft

CASING

Total Length 181 ft.
Casing exposed 18 in.
Diameter 6 in.
Material Steel
Weight 19 lb/ft

LINER OR INNER CASING

Total Length _____ ft.
Depth to liner top _____ ft.
Diameter _____ in.
Material _____
Weight _____ lb/ft
Seal type _____

SCREEN DETAILS

Make/Type _____
Material _____
Diameter _____ in
Depth to screen top _____
Slot size _____
Gravel pack (type/size) _____

WELL LOG

From	To	Formation and water-bearing fracture Information
<u>0</u>	<u>8</u>	<u>Sand & Stones</u>
<u>8</u>	<u>34</u>	<u>Sand</u>
<u>34</u>	<u>107</u>	<u>Hardpan</u>
<u>107</u>	<u>169</u>	<u>Soft Brown schist</u>
<u>169</u>	<u>621</u>	<u>Schist (Grey)</u>

SEALING METHOD

- ☒ Drive Shoe
☒ Grouted – Grout type Portland

YIELD TEST

Tested for 1 hr @ 1100 GPM
Static Water Level _____ ft.
(below land surface)
☐ Overflowing? (check if yes)
☒ Hydrofractured? 1.2 GPM

WELL DRILLER INFORMATION

☒ Yes ☐ No; I provided property owner the Dept. of Health information, per 10 V.S.A. Section 1396(d)

Drilled by: Eric & Nate
Charles Chelala

Signature of Qualifying Individual

Company: Chevalier Drilling Co. Inc.
Lic # 198

COMMENTS AND SITE SKETCH

Received

SEP 19 2014

Drinking Water & Groundwater
Protection Division

White Copy - DWGPD

Yellow Copy - Owner

Pink Copy - Driller

1/10/13