

STATE OF VERMONT – DEPT. OF ENVIRONMENTAL CONSERVATION

Drinking Water & Groundwater Protection Division (DWGPD), 1 National Life Drive, Main Building – 2nd Floor,
Montpelier, VT 05620-3251
Tel. (802) 828-1535 or (802) 585-4907

WELL COMPLETION REPORT

WELL LOCATION

Well Owner or Purchaser: Altan Kolsad
E-911 Address: 524 Maple Rd

WELL TAG No. 49821

Town: Jamaica VT
Subdivision Name: _____
Lot Number: _____

GEOGRAPHIC LOCATION (Complete A OR B, but not both)

Date Well Drilled: 10-29-14

A. GPS Location: 43° 3' 11.42" N 72° 47' 55.67" W
Latitude Rdg Longitude Rdg. GPS Make/Model # of Satellites Used (Min. 3)

B. Attach Town Map with well location marked, if not providing GPS location.

WELL TYPE (Check one)

- ☒ Bedrock
☐ Gravel
☐ Monitoring
☐ Other: _____

WELL USE (Check one)

- ☐ Residential/Non-public
☐ Public water system
☐ Agricultural
☐ Industrial
☒ Other: Pond

REASON FOR WELL (Check one)

- ☒ New supply
☐ Replace existing supply
☐ Deepen existing supply
☒ Additional supply
☐ Test/exploration
☐ Geothermal
☒ Other: FOR POND

WELL CONSTRUCTION INFORMATION

DEPTHS

To bedrock
37 ft.
Total
600 ft

CASING

Total Length 60 ft.
Casing exposed 24 in.
Diameter 6 in.
Material Steel
Weight 19 lb/ft

LINER OR INNER CASING

Total Length _____ ft.
Depth to liner top _____ ft.
Diameter _____ in.
Material _____
Weight _____ lb/ft
Seal type _____

SCREEN DETAILS

Make/Type _____
Material _____
Diameter _____ in.
Depth to screen top _____
Slot size _____
Gravel pack (type/size) _____

WELL LOG

From	To	Formation and water-bearing fracture Information
<u>0</u>	<u>12</u>	<u>Tight sandy gravel</u>
<u>12</u>	<u>37</u>	<u>Fill</u>
<u>37</u>	<u>600</u>	<u>Gray Granite, Quartz</u>

SEALING METHOD

- ☒ Drive Shoe
☒ Grouted – Grout type
BENTONITE

YIELD TEST

Tested for 2 hr @ #1 GPM
Static Water Level 55 ft.
(below land surface)
☐ Overflowing? (check if yes)
☒ Hydrofractured? 11 GPM

WELL DRILLER INFORMATION

☐ Yes ☐ No; I provided property owner the Dept. of Health information, per 10 V.S.A. Section 1396(d)

Drilled by: Mo Le Clair

COMMENTS AND SITE SKETCH

Signature of Qualifying Individual
Company: LC CUSHING & SONS, INC.
Lic # 15.5

Received
NOV 21 2014
Drinking Water & Groundwater Protection Division

White Copy - DWGPD

Yellow Copy - Owner

Pink Copy - Driller

1/10/13

