

VERMONT DEPARTMENT OF ENVIRONMENTAL CONSERVATION  
AUTHORIZATION TO DISCHARGE UNDER  
GENERAL PERMIT 3-9015

A determination has been made that the applicant(s):

Lamoille North Supervisory Union  
736 VT RTE 15 West  
Hyde Park, VT 05655

Impervious Area: 1.45 acres

meets the criteria necessary for inclusion under General Permit 3-9015. Hereinafter the named applicant shall be referred to as the permittee. Subject to the conditions of General Permit No. 3-9015, the permittee is authorized to discharge stormwater as described herein:

*Project Name:* Hyde Park Elementary School Redevelopment

*Project Location:* 50 Main Street in Hyde Park, Vermont

*Receiving Waters:*

- Centerville Brook
- Unnamed tributary to Centerville Brook

*Manner of Discharge:*

S/N 001: Stormwater runoff from the western school access road, walkways, and a portion of the gymnasium rooftop via sheet flow to a catchbasin closed pipe system to unnamed tributary to Centerville Brook.

S/N 002: Stormwater runoff from the loading dock, dumpster pad, and walkways via sheet flow to Centerville Brook.

S/N 003: Stormwater runoff from a portion of the new auxiliary building, basketball court, the existing rooftops, the proposed 3 story building addition, and walkways via sheet flow to a catchbasin closed pipe system to an underground infiltration structure to Centerville Brook.

S/N 004: Stormwater runoff from the new auxiliary building, basketball court, the play structure area, and a portion of the library/classroom roof via sheet flow to a grass-lined swale to Centerville Brook.

S/N 005: Stormwater runoff from the school rooftop, walkways, parking access roads, and parking lot via sheet flow to a catchbasin closed pipe system to an underground infiltration structure, to a stone lined swale to Centerville Brook.

*Design:*

This project shall be constructed and operated in accordance with the site plans and details designed by Civil Engineering Associates, Inc., (Sheet C1.0, "Existing Conditions Plan", dated 12/9/2016, last revised 3/17/2017; Sheet C1.1, "Overall Site Plan", dated 12/9/2016, last revised 3/17/2017; Sheet C1.2, "Utility, Grading & Drainage Plan", dated 12/9/2016, last revised 3/17/2017; Sheet C1.2a, "Erosion Control Plan", dated 12/9/2016, last revised 4/13/2017; Sheet C2.0, "Stormwater Plan", dated 12/9/2016, last revised 3/17/2017; Sheet C2.1, "Storm Details", dated 12/9/2016, last revised 3/17/2017; Sheet C2.2, "Storm Details", dated 12/9/2016, last revised 3/17/2017; Sheet C2.3, "Storm Details", dated 12/9/2016, last revised 3/17/2017; Sheet C2.4, "Storm Details", dated 12/9/2016, last revised 3/17/2017; Sheet C3.3, "Erosion Control Notes and Details", dated 12/9/2016, last revised 3/17/2017; Sheet C3.4, "Erosion Control Details", dated 12/9/2016, last revised 4/13/2017) and all supporting information.

By reference, the above noted plans are made part of this authorization.

Compliance with General Permit 3-9015 and this Authorization

The permittee shall comply with this authorization and all the terms and conditions of General Permit 3-9015, including the payment of annual operating fees to the Department. A billing statement for such fees will be sent to the permittee each year. The first year's statement is enclosed. Any permit non-compliance, including a failure to pay the annual operating fee, constitutes a violation of 10 V.S.A. Chapter 47 and may be grounds for an enforcement action or revocation of this authorization to discharge.

Transferability

This authorization to discharge is not transferable to any person except in compliance with Part VI.D. of General Permit 3-9015. A copy of General Permit 3-9015 is available from the Department via the internet at [http://dec.vermont.gov/sites/dec/files/wsm/stormwater/docs/GeneralPermit9015/sw\\_3-9015\\_final\\_signed.pdf](http://dec.vermont.gov/sites/dec/files/wsm/stormwater/docs/GeneralPermit9015/sw_3-9015_final_signed.pdf).

Changes to Permitted Development

In accordance with Part V.G. of General Permit 3-9015, the permittee shall notify the Department of any planned development or facility expansions or changes that may result in new or increased stormwater discharges. The Department shall determine the appropriateness of continued inclusion under General Permit 3-9015 by the modified development or facility.

Annual Inspection and Report

The stormwater collection, treatment and control system shall be properly operated. The permittee shall submit an annual inspection report on the operation, maintenance and condition of the stormwater collection, treatment and control system. The inspection report shall be submitted regardless of whether the project has been constructed. The inspection shall be conducted between the conclusion of spring snow melt and June 15th of each year and the inspection report shall be submitted to the Secretary by July 15th of each year, or by July 30th if performed by a utility or municipality pursuant to a duly adopted stormwater management ordinance. The inspection report shall note all problem areas and all measures taken to correct any problems and to prevent future problems.

Initial Statement of Compliance

An initial statement of compliance, signed by a designer, must be submitted to the Stormwater Management Program no later than 6 months following completion of construction of the stormwater management system. Failure to submit an initial statement of compliance shall constitute a violation of General Permit 3-9015 and may result in the revocation of this authorization to discharge. Forms for completing this requirement are available on the Stormwater Management Program's website.

Recording in Land Records

The permittee shall record a one-page notice of issuance of this discharge permit in the local land records within fourteen (14) days of issuance of this authorization to discharge on the form provided by the Secretary, per §18-312 of Stormwater Management Rule. The permittee shall provide a copy of the recording to the Stormwater Management Program within fourteen (14) days of the permittee's receipt of the copy of the recording from the local land records.

Renewable Energy Projects – Right to Appeal to Public Service Board

Any appeal of this decision must be filed with the clerk of the Vermont Public Service Board pursuant to 10 V.S.A. §8506 within 30 days of the date of this decision. The appellant must file with the Clerk an original and six copies of its appeal. The appellant shall provide notice of the filing of an appeal in accordance with 10 V.S.A. §8504(c)(2), and shall also serve a copy of the Notice of Appeal on the Vermont Department of Public Service. For information, see the Rules and General orders of the Public Service Board available on line at [www.psb.vermont.gov](http://www.psb.vermont.gov). The address for the Public Service Board is 112 State Street Montpelier, Vermont 05620-2701 (Tel. #802-828-2358).

All Other Projects – Right to Appeal to the Environmental Court

Pursuant to 10 V.S.A. Chapter 220, any appeal of this decision must be filed with the clerk of the Environmental Court within 30 days of the date of the decision. The appellant must attach to the Notice of Appeal the entry fee of \$250.00, payable to the state of Vermont. The Notice of Appeal must specify the parties taking the appeal and the statutory provision under which each party claims party status; must designate the act or decision appealed from; must name the Environmental Court; and must be signed by

the appellant or their attorney. In addition, the appeal must give the address or location and description of the property, project or facility with which the appeal is concerned and the name of the applicant or any permit involved in the appeal. The appellant must also serve a copy of the Notice of Appeal in accordance with Rule 5(b)(4)(B) of the Vermont Rules for Environmental Court Proceedings. For further information, see the Vermont Rules for Environmental Court Proceedings, available on line at [www.vermontjudiciary.org](http://www.vermontjudiciary.org). The address for the Environmental Court is 32 Cherry Street, 2nd Floor Suite 303 Burlington, Vermont 05401 (Tel. # 802-951-1740).


Effective Date and Expiration Date of this Authorization

This authorization to discharge shall become effective on July 18, 2017 and shall continue until July 18, 2022. The permittee shall reapply for coverage at least sixty (60) days prior to July 18, 2022.

Dated Tuesday, July 18, 2017

Emily Boedecker, Commissioner  
Department of Environmental Conservation

By:



Padraic Monks, Stormwater Program Manager  
Stormwater Management Program

**NOTICE OF ISSUANCE OF STORMWATER DISCHARGE PERMIT  
BY THE VERMONT DEPARTMENT OF ENVIRONMENTAL CONSERVATION**

Notice is hereby given that an individual stormwater discharge permit or an authorization to discharge pursuant to a general stormwater discharge permit has been issued by the Vermont Department of Environmental Conservation to Permittee(s) named herein for the discharge of stormwater runoff from impervious surfaces (e.g. roadways, rooftops, parking lots, walkways) pursuant to 10 V.S.A. Section 1264 for the property identified below. The permit/authorization requires treatment and control of stormwater runoff, long-term maintenance of the treatment and control structures and payment of yearly operational fees.

Permittee(s): **Lamoille North Supervisory Union**

Permit/Authorization Number: **7782-9015**

911 Address of Property: **50 Main Street, Hyde Park**

Signature of Permittee or Authorized Representative: \_\_\_\_\_

Printed Name of Permittee or Authorized Representative: \_\_\_\_\_

Date of Signature: \_\_\_\_\_

**Recording information:** Municipal clerks - please index this document listing the State of Vermont, Department of Environmental Conservation as "Grantee". Please index this document listing the above named Permittee(s) as "Grantor(s)". Additionally, if this notice lists the name of a condominium, subdivision or planned community association, please list the named association as an additional "Grantor".

**Please mail this stamped/recorded/completed form to:**

**DEC – Watershed Management Division  
Stormwater Management Program  
1 National Life Drive, Main 2  
Montpelier, VT 05620-3522**

**Or email to: [anr.wsmdstormwatergeneral@vermont.gov](mailto:anr.wsmdstormwatergeneral@vermont.gov)**