



		SOIL PROFILE				<div>Additional Notes</div>  <div>Overview of Test Pit.</div>
		Site Name:	Town Offices			
		Site Location:	Test Pit 1			
Sampling Method:	Excavator	Excavation Date:	12/27/2018			
Excavated Pit Depth:	97"	Start Time:	10:47am			
Depth to Water Table:		N/A	Representative:	KBG		
Overall Site Notes:		Pit excavated by the Town's public works department. Pit located in green space between southeastern corner of park and ride parking lot and VT-15.				
Depth (in)	Soil Type	Additional Sample Description / Notes	Soil Moisture	Soil Color	Photo	
0-4"	Sandy Loam	Organic layer; grassy vegetated overlay; many small roots; granular structure	Slightly Moist	Medium Brown		
4-13"	Loam	Some small to medium roots; granular structure; few coarse fragments with an average diameter of 0.25"	Slightly Moist	Medium Brown		
13-97"	Sand	Fine grain sand; redoximorphic features present including a dark gray ring located 60" from top of pit; granular to subangular blocky structure	Slightly Moist	Light / Medium Brown	