

WASTE MANAGEMENT DIVISION  
103 South Main Street / West Building  
Waterbury, Vermont 05671-0404  
(802) 241-3888  
FAX (802) 241-3296

June 30, 2006

BOB MORAN  
29655 SHELBOURNE ROAD  
PERRYSBURG OHIO 43551

RE: Site Management Activity Completed, Moran Residence  
SMS Site #98-2402, Stowe, Vermont

Dear Mr. Moran:

The Sites Management Section (SMS) has reviewed the most recent analytical results for the sample collected from the water supply serving the above referenced property. The SMS has also reviewed previous reports and information contained in the site file for this property. With this information, the SMS can now make the following conclusions:

- In July of 1998 a release of heating oil occurred from a leaking above ground petroleum storage tank system that serviced the Moran residence.
- Subsequent investigation of the release determined that free phase fuel oil had entered the water supply well casing. The investigation also showed that fuel oil had impacted soils in the vicinity of the fuel tank and supply well.
- During the next several months the fuel oil was removed from the well by utilizing a combination of manual bailing, petroleum sorbent, and product pumps. Once the product levels were sufficiently diminished, a water treatment system was placed on the well to remove dissolved phase contamination.
- A soil vapor extraction system was installed to remediate the contaminated soils. The operation of this system continued until sampling results demonstrated that soil vapors had dropped to acceptable levels.
- Sampling of the water supply well documented gradual decline in contaminant concentrations. The samples collected on April 4, 2006 indicate that no petroleum compounds remain in the supply well at concentrations above detection limits.



Based on the above, the SMS is assigning this site a Site Management Activity Completed (SMAC) designation. This SMAC designation does not release you of any past or future liability associated with the petroleum contamination onsite. It does, however, mean that the SMS is not requesting any additional work in response to the 1998 leak at your property.

Please feel free to call with any questions.

Sincerely,



George Desch, P.E.  
Chief, Sites Management Section

CC: Stowe Selectboard  
Stowe Health Officer  
DEC Regional Office (via electronic mail)